

इंटरनेट

मानक

Disclosure to Promote the Right To Information

Whereas the Parliament of India has set out to provide a practical regime of right to information for citizens to secure access to information under the control of public authorities, in order to promote transparency and accountability in the working of every public authority, and whereas the attached publication of the Bureau of Indian Standards is of particular interest to the public, particularly disadvantaged communities and those engaged in the pursuit of education and knowledge, the attached public safety standard is made available to promote the timely dissemination of this information in an accurate manner to the public.

“जानने का अधिकार, जीने का अधिकार”

Mazdoor Kisan Shakti Sangathan

“The Right to Information, The Right to Live”

“पुराने को छोड़ नये के तरफ”

Jawaharlal Nehru

“Step Out From the Old to the New”

IS 8867 (1978): Saturated vapour pressure and test pressure for low pressure liquefiable gases contained in gas cylinders [MED 16: Gas Cylinders]



“ज्ञान से एक नये भारत का निर्माण”

Satyanarayan Gangaram Pitroda

“Invent a New India Using Knowledge”



“ज्ञान एक ऐसा खजाना है जो कभी चुराया नहीं जा सकता है”

Bhartrhari—Nitiśatakam

“Knowledge is such a treasure which cannot be stolen”

BLANK PAGE



Indian Standard

SATURATED VAPOUR PRESSURE
AND TEST PRESSURE FOR LOW PRESSURE
LIQUEFIABLE GASES CONTAINED IN
GAS CYLINDERS

(First Reprint MARCH 1983)

UDC 661.91-404-984 : 533.21 : 621.642.02



© Copyright 1978

INDIAN STANDARDS INSTITUTION
MANAK BHAVAN, 9 BAHADUR SHAH ZAFAR MARG
NEW DELHI 110002

Indian Standard

SATURATED VAPOUR PRESSURE AND TEST PRESSURE FOR LOW PRESSURE LIQUEFIABLE GASES CONTAINED IN GAS CYLINDERS

Gas Cylinders Sectional Committee, EDC 16

Chairman

SHRI I. N. MURTY

Representing

Chief Controller of Explosives (Ministry of Industry), Nagpur

Members

SHRI CHARANJIT LAL (Alternate to Shri I. N. Murty)	
SHRI S. P. ADARKAR	Indian Oil Corporation Ltd, Bombay
SHRI A. K. VATTS (Alternate)	
SHRI P. K. AGARWALA	Hindustan Gas & Industries Ltd, Farbangla
SHRI M. R. ANANTHANARAYANAN	A. M. Testing Services Private Ltd, Hyderabad
SHRI P. D. ARTE	Shri Ambica Cylinder Manufacturing Co Ltd, Ahmadabad
SHRI V. S. GAONKAR (Alternate)	
SHRI A. BALAKUMAR	Hyderabad Allwyn Metal Works Ltd, Hyderabad
SHRI J. D. MURTY (Alternate)	
SHRI R. R. BHALLA	Hindustan General Industries Ltd, Nangloi
SHRI D. P. ANAND (Alternate)	
SHRI B. J. DOODHMAL	Kosan Metal Products Pvt Ltd, Bombay
SHRI G. L. NEEMA (Alternate)	
SHRI D. K. GARG	The Industrial Gases Ltd, Calcutta
SHRI S. L. ROY (Alternate I)	
SHRI S. K. SANGAL (Alternate II)	
SHRI A. GHOSH	National Test House, Calcutta
SHRI J. N. GOSWAMY	Lloyd's Register of Shipping, Bombay
SHRI D. MADHOK (Alternate I)	
SHRI H. T. PAVRI (Alternate II)	

(Continued on page 2)

© Copyright 1978

INDIAN STANDARDS INSTITUTION

This publication is protected under the Indian Copyright Act (XIV of 1957) and reproduction in whole or in part by any means except with written permission of the publisher shall be deemed to be an infringement of copyright under the said Act.

(Continued from page 1)

<i>Members</i>	<i>Representing</i>
SHRI G. K. KABRA	Ideal Engineers Hyderabad Pvt Ltd, Hyderabad
SHRI M. KALIDAS	Kaveri Engineering Industries Pvt Ltd, Tiruchirappalli
SHRI V. S. RAMKUMAR (Alternate)	
SHRI R. L. KAUL	Tata Chemicals Ltd, Mithapur
SHRI B. T. GAJJAR (Alternate)	
SHRI S. K. KHANDEKAR	Vanaz Engineers Private Ltd, Pune
SHRI S. R. SARWATE (Alternate)	
SHRI P. KISHORE	The Asiatic Oxygen & Acetylene Co Ltd, Calcutta
SHRI M. MITRA (Alternate)	
SHRI M. C. KUMARASWAMY	Tata Iron & Steel Co Ltd, Jamshedpur
SHRI A. B. MALLIK	Directorate General of Technical Development, New Delhi
DR S. R. MEHTA	Fabrication Surveyors (India), Bombay
SHRI B. N. MURTHY	Bokaro Steel Ltd, Bokaro
SHRI K. V. PAI (Alternate)	
SHRI K. K. PANDE	Bharat Pumps & Compressors Ltd, New Delhi
SHRI S. L. DUA (Alternate)	
SHRI L. M. PASRICHA	Association of Indian Engineering Industry, New Delhi
SHRI B. K. GHOSH (Alternate)	
SHRI E. M. PATEL	Indian Gas Cylinders, Faridabad
REPRESENTATIVE	Ministry of Defence (DGI)
SHRI L. C. BHANDARI (Alternate)	
SHRI A. K. SHARMA	Gannon Dunkerley & Co Ltd, Bombay
SHRI S. V. KULKARNI (Alternate)	
SHRI D. D. SHARMA	The Indian Sugar & General Engineering Corpora- tion, Yamunanagar
SHRI N. K. GUPTA (Alternate)	
SHRI S. D. SINGH	Indian Oxygen Ltd, Calcutta
SHRI L. M. PASRICHA (Alternate)	
SHRI T. P. L. SINHA	Indian Air Gases Ltd, Moghalsarai
SHRI S. C. SRIVASTAVA	Steel Authority of India Ltd, New Delhi
SHRI S. D. SHARMA (Alternate)	
SHRI T. N. SRIVASTAVA	Ministry of Defence (R & D)
SHRI M. D. SAHU (Alternate)	
COL SUKHDEV SINGH	National Safety Council, Bombay
SHRI N. RAGHAVAN (Alternate)	
SHRI H. K. TANEJA	Indian Register of Shipping, Bombay
SHRI S. CHANDRA (Alternate)	
SHRI P. S. VISVANATH	Advani-Oerlikon Ltd, Bombay
SHRI S. D. SAWANT (Alternate)	
SHRI S. CHANDRASEKHARAN,	Director General, ISI (Ex-officio Member)
Deputy Director (Mech Engg)	

Secretary

SHRI A. S. KOHLI
Deputy Director (Mech Engg), ISI

(Continued on page 10)

Indian Standard

SATURATED VAPOUR PRESSURE AND TEST PRESSURE FOR LOW PRESSURE LIQUEFIABLE GASES CONTAINED IN GAS CYLINDERS

0. FOREWORD

0.1 This Indian Standard was adopted by the Indian Standards Institution on 27 April 1978, after the draft finalized by the Gas Cylinders Sectional Committee had been approved by the Mechanical Engineering Division Council.

0.2 Manufacture, possession and use of any gas when contained in cylinders, in compressed or liquefied state is regulated under the Gas Cylinder Rules, 1940, of the Government of India as amended from time to time. This standard has been prepared in consultation and agreement with the statutory authorities under those rules.

0.3 This standard has been prepared for the guidance of the designers, users, manufacturers and fillers of gas cylinders for low pressure liquefiable gases to ensure their safe design, handling and use.

0.4 Indian Standards Institution has already published the following specifications for gas cylinders for low pressure liquefiable gases:

IS : 3196-1974 Welded low carbon steel gas cylinder exceeding 5-litre water capacity for low pressure liquefiable gases (*second revision*)

IS : 7142-1974 Welded low carbon steel gas cylinders for low pressure liquefiable gases, not exceeding 5-litre water capacity

IS : 7680-1975 Welded low carbon steel gas cylinders for ammonia (anhydrous) gas

IS : 7681-1975 Welded low carbon steel gas cylinders for chlorine gas

IS : 7682-1975 Welded low carbon steel gas cylinders for methyl bromide gas

0.5 The maximum internal pressure, p_d which a low pressure liquefiable gas when contained in a cylinder can develop, is its saturated vapour pressure at the maximum attainable temperature, which is taken as 65°C in India. In the case of low pressure liquefiable gases, the saturated vapour pressure is independent of the filling ratio (*see* IS : 3710-1978*).

However, in the design of cylinders a safety factor of 1.5 is used. Therefore, the pressure to be used in the formulae for calculating the wall thickness of the gas cylinder (which is same as the hydrostatic test pressure) of cylinders containing low pressure liquefiable gas theoretically equals 1.5 times the saturated vapour pressure of the gas at 65°C.

0.6 The values of saturated vapour pressure (which equals the maximum developed pressure) at 65°C, p_d , and the minimum theoretical test pressure, p_{ht} , given in this standard hold good only for pure gases. The presence of any impurity will give rise to higher pressures and, therefore, such cylinders should be designed to withstand higher pressures.

0.7 The recommended test pressures, p_h , given in this standard are not less than 1.5 times the saturated vapour pressure of the gas at 65°C, p_d , subject to a minimum of 18 kgf/cm². However, in the interests of industrial standardization, to account for the impurities present and to facilitate the change of cylinders from one gas service to another, the values of minimum recommended test pressures, p_h have been rationalized. Thus for 50 different gases the number of test pressure values has been rationalized to about 10 only. In the interest of safety, particularly due to the poisonous nature of certain gases, still higher test pressure has been recommended in the case of such gases. In all cases, however, cylinders should be tested at the pressure marked on the cylinder.

0.8 Presently there are a number of cylinders in circulation which have earlier been permitted by the statutory authority to be tested at a test pressure which is different from that recommended in this standard. At the time of periodical inspection, all such cylinders should be tested at the test pressure marked on the cylinder.

0.9 This standard is based on BS 5355 : 1976 ' Filling ratios and developed pressures for liquefiable and permanent gases ' issued by the British Standards Institution. Data from some other sources has also been taken in a few cases.

*Filling ratios for low pressure liquefiable gases contained in cylinders (*first revision*).

0.10 The quantities in this standard have been expressed in technical metric units. However, in view of the introduction of International System (SI) units in the country, the relevant SI units and the corresponding conversion factors are given below for guidance:

$$\begin{aligned} 1 \text{ kgf/cm}^2 &= 98.0665 \text{ kPa (kilopascal)} \\ &= 0.0980665 \text{ MPa (megapascal)} \\ &= 0.980665 \text{ bar} \end{aligned}$$

0.11 For the purpose of deciding whether a particular requirement of this standard is complied with, the final value, observed or calculated, expressing the result of a test or analysis, shall be rounded off in accordance with IS : 2-1960*. The number of significant places retained in the rounded off value should be the same as that of the specified value in this standard.

1. SCOPE

1.1 This standard specifies the values of the saturated vapour pressure at 65°C, and the recommended test pressures for low pressure liquefiable gases contained in gas cylinders.

2. TERMINOLOGY

2.1 For the purpose of this standard, the following definitions in addition to those given in IS : 7241-1974† shall apply.

2.1.1 Low Pressure Liquefiable Gas — A liquefiable gas having a critical temperature above 70°C.

2.1.2 Hydrostatic Test Pressure, p_h — Pressure to which a cylinder is subjected to in the hydrostatic pressure test.

2.1.3 Design Pressure — Pressure used in the design calculations of a cylinder for the purpose of determining its minimum wall thickness.

NOTE — Design pressure is taken as equal to the hydrostatic test pressure.

2.1.4 Maximum Developed Pressure, p_d — The internal pressure developed by the gas at the maximum attainable temperature of 65°C. In the case of low pressure liquefiable gases, it equals the saturated vapour pressure of the gas at the temperature of 65°C.

3. SATURATED VAPOUR PRESSURE AND TEST PRESSURE

3.1 The values of the saturated vapour pressure at 65°C, p_d , theoretical minimum test pressure, p_{ht} , and the recommended test pressure, p_h for low pressure liquefiable gases are given in Table 1.

*Rules for rounding off numerical values (revised).

†Glossary of terms used in gas cylinders technology.

TABLE 1 SATURATED VAPOUR PRESSURE AND TEST PRESSURE

(Clause 3.1)

NAME OF GAS	CHEMICAL SYMBOL	SATURATED VAPOUR PRESSURE, p_d AT 65°C, kgf/cm ² (GAUGE)	THEORETICAL Min TEST PRESSURE $p_{ht} = (1.5 p_d)$, kgf/cm ² (GAUGE)	RECOMMENDED TEST PRESSURE, p_h kgf/cm ² (GAUGE)	CRITICAL TEMPERATURE
(1)	(2)	(3)	(4)	(5)	(6)
Ammonia	NH ₃	29.04	43.56	45	+132.4°C
Boron trichloride	BCl ₃	4.06	6.09	60†	+178.8°C
Butadiene (vinylethylene, divinyl)	C ₄ H ₆	7.36	11.04	18	+152°C
Butane (normal)	C ₄ H ₁₀	6.32	9.48	18	+152°C
Butene	C ₄ H ₈	—	—	18	+146.4°C
Chlorine	Cl ₂	19.90	29.85	30	+144°C
Chlorine trifluoride	ClF ₃	6.26	9.39	18	+153°C
Cyanogen	(CN) ₂	16.17	24.26	100†	+128°C
Cyanogen chloride	ClCN	4.71	7.06	100†	+174°C
Cyclopropane	C ₃ H ₆	19.06	28.59	30	+124.4°C
Dichlorodifluoromethane (R-12*)	CCl ₂ F ₂	16.29	24.44	25	+112°C
Dichloromonofluoromethane (R-21*)	CHCl ₂ F	5.04	7.56	18	+178.5°C
1.2 Dichlorotetrafluoroethane (R-114*)	CClF ₂ CClF ₂	5.60	8.40	18	+145.7°C
1.1 Difluoroethane (ethylidene fluoride) (R-152a*)	CH ₃ CHF ₂	16.17	24.26	25	+113.5°C
Dimethylamine	(CH ₃) ₂ NH	6.13	9.20	18	+164.6°C
Dimethylether (methyl ether, methyl oxide)	(CH ₃) ₂ O	15.47	23.20	25	+126.9°C

Ethylamine (aminoethane)	$C_2H_5NH_2$	4.06	6.09	18	+183°C
Ethyl chloride (chloroethane)	C_2H_5Cl	4.45	6.68	18	+187.2°C
Ethylene oxide	C_2H_4O	4.92	7.38	18	+195.8°C
Hydrogen cyanide (anhydrous)	HCN	2.81	4.22	100†	+183.5°C
Hydrogen fluoride (anhydrous)	HF	3.32	4.98	18	+188°C
Hydrogen sulphide	H_2S	48.07	72.10	75	+100.4°C
Isobutane (2-methyl propane) (R-600a*)	$CH(CH_3)_3$	8.82	13.23	18	+135°C
Isobutylene	$CH_2=C(CH_3)_2$	7.74	11.61	18	+144.73°C
LPG‡ (liquefied petroleum gas)	—	16.87	25.30	25	—
Methylmercaptan (methanethiol)	CH_3SH	—	—	18	+196.8°C
Methylamine (aminomethane)	CH_3NH_2	11.03	16.54	18	+156.9°C
Methyl bromide	CH_3Br	5.70	8.55	18	+191°C
Methyl chloride	CH_3Cl	14.92	22.38	25	+143.1°C
Monochlorodifluoroethane (R-142b*)	CH_3CClF_2	9.15	13.71	18	+137°C
Monochlorodifluoromethane (R-22*)	$CHClF_2$	26.71	40.06	45	+96°C
Monochloromonobromodi- fluoromethane (R-12B ₁)	$CClF_2Br$	7.07	10.60	18	+153.8°C

*This is the refrigerant number of the gas in accordance with ISO/R 817 - 1974 'Organic refrigerants — Number designation' issued by the International Organization for Standardization.

†Due to the high toxicity of the gas, the value of recommended test pressure, p_h , is considerably higher than that of theoretical test pressure, p_{ht} .

‡The value of saturated vapour pressure for LPG varies depending upon the proportion of constituent gases. The value given here should not, therefore, be taken as absolute value.

(Continued)

TABLE 1 SATURATED VAPOUR PRESSURE AND TEST PRESSURE — Contd

NAME OF GAS	CHEMICAL SYMBOL	SATURATED VAPOUR PRESSURE, p_d AT 65°C, kgf/cm ² (GAUGE)	THEORETICAL <i>Min</i> TEST PRESSURE $p_{ht} = (1.5 p_d)$, kgf/cm ² (GAUGE)	RECOMMENDED TEST PRESSURE, p_h kgf/cm ² (GAUGE)	CRITICAL TEMPERATURE
(1)	(2)	(3)	(4)	(5)	(6)
Monochloropentafluoroethane (R-115*)	CClF ₂ CF ₃	22.48	33.78	35	+79.9°C
Monochlorotetrafluoroethane (R-124a*)	CHF ₂ CClF ₂	5.98	8.97	18	—
Monochlorotrifluoroethane (R-133a*)	CH ₂ ClCF ₃	5.81	8.72	18	+144.2°C
Monochlorotrifluoroethylene (R-1113*)	CClF=CF ₂	16.53	24.80	25	+107°C
∞ Nitrogen tetroxide (nitrogen peroxide)	N ₂ O ₄	5.25	7.88	60†	+158°C
Nitrosyl chloride	NOCl	10.79	16.18	50†	+173°C
Octafluorocyclobutane (R-C318*)	C ₄ F ₈	8.74	13.11	18	+114.2°C
Phosgene (carbonyl chloride)	COCl ₂	5.18	7.77	60†	+182°C
Propane	C ₃ H ₈	22.66	33.99	35	+96.8°C
Propene	C ₃ H ₆	27.29	40.94	45	+91.8°C
Refrigerant gas mixture R 500* (R 12*, 73.8% + R 152a*, 26.2%, by mass)	—	19.58	29.37	30	+105°C
Refrigerant gas mixture R 502* (R 22* 48.8% + R 115* 51.2%, by mass)	—	28.01	42.01	45	+90.1°C

Refrigerant mixture (R 12* 88%+ ethylene oxide 12%, by mass)	—	13·38	20·07	25	—
Sulphur dioxide	SO ₂	11·95	17·92	18	+157·5°C
Trichloromonofluoromethane (R-11*)	CCl ₃ F	2·63	3·94	18	+198°C
Trimethylamine	(CH ₃) ₃ N	5·70	8·55	18	+160·2°C
Vinyl bromide	CH ₂ =CHBr	—	—	18	+200°C
Vinyl chloride	CH ₂ =CHCl	10·60	15·90	18	+156·5°C
Vinylmethyl ether	CH ₃ OCH=CH ₂	5·62	8·43	18	—

*This is the refrigerant number of the gas in accordance with ISO/R 817-1974 'Organic refrigerants — Number designation' issued by the International Organization for Standardization.

†Due to the high toxicity of the gas, the value of recommended test pressure, p_h , is considerably higher than that of theoretical test pressure, p_{ht} .

(Continued from page 2)

Low Pressure Gas Cylinders Subcommittee, EDC 16 : 2

Convener

SHRI E. M. PATEL

Representing

Indian Gas Cylinders, Faridabad

Members

SHRI S. P. ADARKAR	Indian Oil Corporation Ltd, Bombay
SHRI A. K. VATTS (<i>Alternate</i>)	
SHRI A. BALAKUMAR	Hyderabad Allwyn Metal Works Ltd, Hyderabad
SHRI J. D. MURTY (<i>Alternate</i>)	
SHRI B. J. DOODMAL	Kosan Metal Products Private Ltd, Bombay
SHRI S. R. PALEKAR (<i>Alternate</i>)	
SHRI VIDYANATH S. GAONKAR	Shri Ambica Cylinder Manufacturing Co Ltd, Ahmadabad
SHRI PARESH M. NADKARNI (<i>Alternate</i>)	
SHRI D. K. GARG	The Industrial Gases Ltd, Calcutta
SHRI S. L. ROY (<i>Alternate I</i>)	
SHRI S. K. SANGAL (<i>Alternate II</i>)	
SHRI J. N. GOSWAMY	Lloyd's Register of Shipping, Bombay
SHRI D. MADHOK (<i>Alternate I</i>)	
SHRI H. T. PAVRI (<i>Alternate II</i>)	
SHRI I. N. MURTY	Chief Controller of Explosives (Ministry of Industry), Nagpur
SHRI CHARANJIT LAL (<i>Alternate</i>)	
SHRI R. R. NAGARKATTI	Hindustan Petroleum Corporation Ltd, Bombay
SHRI M. S. GULWADI (<i>Alternate</i>)	
SHRI A. K. SHARMA	Gannon Dunkerley & Co Ltd, Bombay
SHRI S. V. KULKARNI (<i>Alternate</i>)	
SHRI D. D. SHARMA	Indian Sugar & General Engineering Corporation Ltd, Yamunanagar
SHRI P. C. SILAICHIA	Bharat Refineries Ltd, Bombay
SHRI S. L. ARANHA (<i>Alternate</i>)	
SHRI S. D. SINGH	Indian Oxygen Ltd, Calcutta
SHRI B. K. GHOSH (<i>Alternate</i>)	
SHRI R. N. SOOD	Caltex Oil Refining (India) Ltd, Bombay
SHRI S. NANDA (<i>Alternate</i>)	